



TOWN PLANNING AND BUILDING CONTROL  
06 JUN 2013  
RECEIVED

- GENERAL NOTES:**
- CONCRETE TO BE GRADE 30 DESIGN MIX FOR ORDINARY STRUCTURAL CONCRETE IN ACCORDANCE WITH S.S. 810:1995
  - CONCRETE TO BE MECHANICALLY VIBRATED
  - ALL CONCRETE SURFACE TO BE FREE FROM HOLES, HONEYCOMBING AND OTHER DEFECTS
  - CONCRETE COVER TO ALL REINFORCEMENT TO BE 40MM UNLESS OTHERWISE STATED
  - POSITION OF CONSTRUCTION JOINTS TO BE AGREED WITH THE ENGINEER ON SITE
  - ALL REINFORCED CONCRETE STRUCTURAL MEMBERS TO BE ADEQUATELY CURVED AND PROTECTED
  - THE ENGINEER RESERVES RIGHT TO REQUIRE ANY CONCRETE THAT DOES NOT COMPLY WITH THE REQUIREMENTS OF THE SPECIFICATION TO BE ENTIRELY REMOVED AND RECONSTRUCTED AT THE CONTRACTOR'S EXPENSE
  - 8MM REINFORCEMENT TO BE COLD WORKED TYPE 3 BARS CONFORMING WITH BS 4449:1999 AND BENT IN ACCORDANCE WITH BS 4449:1999
  - FABRIC MESH REINFORCEMENT SHEETS TO COMPLY WITH BS 4449:1999 AND TO BE CUT ON SITE
  - MINIMUM LAP BETWEEN FABRIC MESH REINFORCEMENT SHEETS TO BE 300mm
  - HANDWORK TO BE 180MM MIN THICKNESS & TO BE WELL COMPACTED FOR MAXIMUM CONSOLIDATION
  - THE CONTRACTOR IS RESPONSIBLE FOR ENSURING THE STABILITY OF THE SITE AND WORKS, INCLUDING ADJACENT SITES AND HIGHWAYS, AND ALL SERVICES THROUGHOUT THE CONSTRUCTION
  - ALL THE EXCAVATIONS AND THE SURROUNDING SITE TO BE KEPT FREE OF WATER
  - THE GROUND BELOW G.C. FOUNDATIONS TO BE BLANDED WITH 50MM THICK LAYER OF CONCRETE AND COMPACTED TO BE CAST WITHOUT DELAY FOLLOWING EXCAVATION TO FORMATION LEVELS AND APPROVAL OF THE SURVEYOR
  - THE DESIGN OF THE FOUNDATIONS IS BASED ON THE ASSUMPTION THAT THE SOIL AT FORMATION LEVEL CAN SAFELY SUSTAIN THE IMPOSED PRESSURE OF 300kN/m<sup>2</sup> FOCUSES OF HEAVIER SOIL FOUND AT THIS LEVEL SHALL BE INDICATED AND THE LEVELS LIFT WITH MASS CONCRETE
  - THE ENGINEER'S APPROVAL MUST BE OBTAINED PRIOR TO ALTERING THE FORMATION LEVELS SHOWN ON THE DRAWINGS
  - FILL MATERIALS TO BE DEPOSITED IN LAYERS 200MM THICK AND TO BE WELL COMPACTED FOR MAXIMUM CONSOLIDATION
- STEEL WORK:
- ALL WELDS TO BE CONTINUOUS UNLESS OTHERWISE STATED
  - THE CONTRACTOR IS RESPONSIBLE FOR THE CORRECT SETTING OUT OF THE WORKS ON SITE AND ALSO FOR REFERRING ANY DIMENSIONAL DISCREPANCIES TO THE S.O. PRIOR TO ANY ACTION BEING TAKEN
  - THE CONTRACTOR IS RESPONSIBLE FOR THE STABILITY OF THE BUILDING DURING THE CONSTRUCTION PERIOD
  - ALL STRUCTURAL STEEL TO BE GRADE S460 N 430
  - ALL DIMENSIONS MUST BE CHECKED ON SITE AND NOT SCALED FROM THE DRAWINGS
  - FIRE EXIST SIGN TO BS 5489 PART 4

Rev.	Drawn	Chkd.	Date	Description
	J.RUSSO	John Baldashino		

H.M. Government of Gibraltar  
Technical Services Department  
Joshua Hassan House  
Secretary's Lane  
Gibraltar

Job Title  
**Camp Bay Ramps**

Drawing Title  
**Ramp 2 Toilet Ramp Site Layout and Elevation**

Drawn	Checked
J.RUSSO	John Baldashino

Date	Scale (at A1)
09-04-13	As Shown

Drg. No.	Rev.
88/118	