



KEY:

FLOOR FINISHES:

- F1 INTERNAL CERAMIC TILING ANTI-SLIP CERAMIC TILING. SEE NBS SPEC. SECTION M40. FINISHES AS PER THE C600 SERIES FINISHES DRAWINGS.
- F2 VINYL TARKETT VINYL FLOORING. SEE NBS SPEC. SECTION M50. COLOURS/TYPES AS PER THE C600 SERIES FINISHES DRAWINGS.
- F4 TILING TO EXTERNAL TERRACES. EXTERNAL QUALITY ANTI-SLIP CERAMIC TILE - SEE NBS SPEC. SECTION M40.
- F6 ENTRANCE CLEAN-OFF MATTING. SEE NBS SPEC. SECTION N10. REFER TO THE C600 SERIES FINISHES DRAWINGS.

WALL FINISHES:

- W1 STERISHIELD QUICKDRYING EGGSHELL FROM DULUX TRADE - ANTI-BACTERIAL PAINT. SEE NBS SPEC. SECTION M40. COLOUR CHOICES AS PER THE C600 SERIES FINISHES DRAWINGS.
- W2 (ENSUITES & TOILETS (WITHOUT SHOWERS) WALLS). CERAMIC TILING UP TO DADO HEIGHT WITH DULUX (TRADE) STERISHIELD QUICKDRYING EGGSHELL ANTI-BACTERIAL PAINT ABOVE.
- W3 (ENSUITES & TOILETS (WITH SHOWERS) WALLS). FULL HEIGHT CERAMIC TILING. COLOUR CHOICES AS PER THE C600 SERIES FINISHES DRAWINGS. SEE NBS SPEC. SECTION M40. REFER TO THE C600 SERIES FINISHES DRAWINGS.
- W4 CERAMIC TILE WORKTOP SPLASHBACK (KITCHEN AREAS). SEE NBS SPEC. SECTION M40. REFER TO THE C600 SERIES FINISHES DRAWINGS.
- W4 PVC WORKTOP SPLASHBACK. REFER TO THE C600 SERIES FINISHES DRAWINGS. SEE NBS SPEC. SECTION P20.

CEILING FINISHES:

- C1 BRITISH GYPSUM CASOLINE W/ SUSPENDED CEILING SYSTEM. SEE NBS SPEC. SECTION K10.
- C2 BURGESS AIR CONCEALED GRID STANDARD CLIP-IN METAL TILE SUSPENDED CEILING SYSTEM WITH BIOCOTE PPC FINISH. SEE NBS SPEC. SECTION K40.
- C3 BRITISH GYPSUM DYPLINER UNIVERSAL SYSTEM DIRECTLY FIXED TO UNDERSIDE OF JOISTS / BATTENS. SEE NBS SPEC. SECTION K10.
- C4 FIRE PROOFING UNDERSIDE OF TIMBER FLOORS: BRITISH GYPSUM FIRELINE BOARD DIRECTLY FIXED TO UNDERSIDE OF JOISTS. SEE NBS SPEC. SECTION K10.
- C5 12MM THICK CEMENT BOARD CEILING ON TREATED SOFTWOOD TIMBER FRAMING. CEMENT BOARD TO RECEIVE AN ACRYLIC RENDER SYSTEM FINISH. TIMBER FRAMING TO BE FIXED TO EXISTING STRUCTURAL BEAMS SLAB. SEE NBS SPEC. SECTIONS K11, M20 & G20.

WALL & CEILING FEATURES:

ALL CORRIDOR WALLS TO RECEIVE CORNER GUARDS AT CORNER LOCATIONS. CS ACRYLON SURFACE MOUNTED CORNER GUARD 50-10/ 50-20. TO BE INSTALLED IN STRICT ACCORDANCE WITH THE MANUFACTURERS RECOMMENDATIONS AND INSTRUCTIONS.

CS ACRYLON PLATFORM HANDRAIL P-OW TO ALL CORRIDORS. EXACT TYPE AND FINISH TO BE CONFIRMED.

DADO RAILS TO ALL BEDROOMS AND LIVING/DINING AREAS. EXACT TYPE AND FINISH TO BE CONFIRMED.

CEILING COVING THROUGHOUT EXCEPT CORRIDORS AND MAIN KITCHEN. EXACT TYPE AND FINISH TO BE CONFIRMED.

*NOTE: DRAWINGS TO BE READ IN CONJUNCTION WITH THE C600 SERIES FINISHES DRAWINGS.

PARTITION KEY

PARTITION WALLS GENERALLY:
BRITISH GYPSUM GYPSUM WALL CLASSIC ONE OUTER LAYER OF 15mm DURALINE BOARD & ONE INNER LAYER OF 12.5mm SOUNDBLOCK BOARD EACH SIDE OF 70mm GYPSUM 'C' STUDS AT 600mm CENTRES. 25mm ISOVER APR 1200 IN THE CAVITY. (OVERALL THICKNESS OF PARTITION 127mm). 90MIN FIRE RATING

BRITISH GYPSUM SHAFTHALL PARTITION SYSTEM:
CONSISTING OF 70mm METAL 'V' STUDS WITH GYPSOCORE BOARD BETWEEN STUDS, 25mm ISOVER APR 1200 CAVITY INSULATION AND WITH ONE LAYER OF 15mm DURALINE BOARD AND ONE LAYER OF 12.5mm FIRELINE BOARD TO NON-SHAFT SIDE. (OVERALL THICKNESS OF PARTITION 100mm). 80 MIN FIRE RATING

EXISTING MASONRY WALLS - VARIOUS THICKNESSES.

BLOCKWORK WALL - SEE NBS F10

BRICKWORK WALL - SEE NBS F10

NOTES
Do not scale from this drawing. Only figured dimensions are to be taken from this drawing.

Contractor must verify all dimensions on site before commencing any work or shop drawings.

Work within the Gibraltar Construction (Design & Management) Regulations not to start until a Health and Safety Plan has been produced.

This Drawing is Copyright and must not be reproduced without consent of GCArchitects.

This drawing originates from the CAD file:
Project: 7

| Rev. | Description | Drawn Date | Checked Date |
|------|--|--------------|--------------|
| A | D11.1 changed from single to double door | JOR 18.11.10 | |
| B | Updated Revisions as bubbled | JOR 18.12.10 | |
| C | Revisions as noted and bubbled | JOR 20.01.11 | |
| D | New Clients Brief Construction Issue | JOR 13.12.12 | |
| E | BLOCK H UPDATED; MINOR AMENDMENTS. | JJC 14.05.13 | |
| F | BLOCK H & BLOCK C BASEMENT UPDATED | JJC 20.06.13 | |

GENERAL NOTES

DRAWING TO BE READ IN CONJUNCTION WITH NBS SPECIFICATION. ONLY SELECTED NBS REFERENCES ARE SHOWN ON THIS DRAWING. PLEASE NOTE THAT CONTRACTOR IS RESPONSIBLE FOR FULL CROSS REFERENCING OF NBS SPECIFICATION AND DRAWINGS.

ALL DIMENSIONS GIVEN ARE IN MILLIMETRES AND MUST BE CHECKED ON SITE AND NOT SCALED FROM THESE DRAWINGS.

ALL WRITTEN DIMENSIONS TO BE CHECKED ON SITE BY CONTRACTORS / SUPPLIERS.

ALL MATERIALS AND FITTINGS TO BE TO BRITISH STANDARDS AND BEST QUALITY.

ALL WORKS TO COMPLY WITH LATEST GIBRALTAR CDM AND HEALTH & SAFETY REGULATIONS.

ALL AREAS DISTURBED OR EXPOSED DURING WORKS TO BE MADE GOOD TO MATCH EXISTING ADJACENT.

THE CONTRACTOR IS TO PROVIDE SAMPLES OF EXACT FINISHES AND FITTINGS TO BE APPROVED PRIOR TO PLACEMENT OF ORDERS AND/OR PROCEEDING WITH THE WORKS.

ALL ARISINGS TO BE CARTED AWAY AND DISPOSED OF IN ACCORDANCE WITH LOCAL REGULATIONS.

ALL COLUMNS AND STRUCTURAL ELEMENTS ARE INDICATIVE ONLY. REFER TO STRUCTURAL ENGINEER'S DRAWINGS FOR ALL STRUCTURAL ELEMENTS.

FOR M&E WORK REFER TO M&E ENGINEER'S DRAWINGS AND SPECIFICATION.

GCArchitects, Gibraltar.

CONSTRUCTION

Date: 03/11/10 Signed: JJC

GCArchitects

Members of the Royal Institute of British Architects

GCArchitects Ltd., Suite 1, First Floor, 23 Horse Barrack Lane, GIBRALTAR.
T: (350) 495901, F: (350) 495921, E: info@gcarchitects.gi, W: www.gcarchitects.gi

PROJECT
Government of Gibraltar
Former Royal Naval Hospital
Gibraltar

DRAWING TITLE
Block B - Dementia Therapy
Level 1: Basement Floor Plan

| Scale | Drawn By | Checked By |
|-----------|------------|--------------|
| 1:50 @ A1 | JOR | JJC |
| | Date Drawn | Date Checked |
| | 16/07/10 | |

Display Block **CONSTRUCTION**

DRAWING NO. **09012/B/C200 Rev. F**